



### 10-0137 - Surelite™ Electronic Ballast

# Specifications -

Model Number: 10-0137 120v AC Input Voltage: Frequency: 50/60 Hz.

Lamp Types: See Chart On Next Page

Certifications: UL #E191525 Size: 6.5" x 1.5" x 1.0"

> Weight: 10 oz.

Mounting: Slotted Mounting Tabs





- 1. Ground case in accordance with the National Electric Code.
- 2. Remote mounting distance varies with lamp type; consult factory with requirements.
- 3. When connecting two RED wires, they must be joined to make one wire before connecting to the lampholder.
- 4. For miniature bipin lamps as well as medium bipin lamps, add jumper between socket contacts, of the lampholder, before connecting the RED and YELLOW wires. (See over)





WARNING: Install in accordance with the national and local electrical code. Disconnect power before servicing. Ballast must be grounded. ATTENTION: L'installation doit être

conforme aux normes du code national électrique. Débranchez l'alimentation avant l'entretien. Le ballast doit être mis à la terre.

RFI, EMI: SOUND RATING: CLASS: 70°C max. TYPE MAX. VOLTAGE OUTPUT: CIRCUIT OR TO GROUND: INSTANT START: MIN. BALLAST START: MIN. LAMP START:

INPUT: MAXIMUM CURRENT: 0.56A FCC Part 18A 1 or 2 Outdoor

600VAC

See Lamp Specs APPROVED FOR LAMP COMBINATIONS OF 64 MAX. WATTS OF CFS/4P, CFT/4P, CFO/4P, CFM/4P, CIRCLINE, LINEAR T5HO, T8, T8HO, T10, T12 & T12HO LAMPS, WHEN USED PER WIRING SPECS

回览 Visit <u>ultraviolet.com/wiringdiagrams/</u> for instructions and wiring-diagram



lSurelite

The information and recommendations contained in this publication are based upon data collected by the Atlantic Ultraviolet Corporation® and are believed to be correct. However, no guarantee or warranty of any kind, expressed or implied, is made with respect to the information contained herein. Specifications and information are subject to change without notice.






### 10-0137 - Surelite™ Electronic Ballast


# Lamp Types -

Lamp Types	Wiring Diagram
MIGHTY*PURE® MP16A, SANITRON® S17A Lamp Part No. 05-1098-R	1
MIGHTY*PURE® MP22A, SANITRON® S23A Lamp Part No. 05-1097-R	1
MIGHTY*PURE® MP36C, SANITRON® S37C Lamp Part No. 05-1343-R	2
MIGHTY* PURE® MP49C, SANITRON® S50C Lamp Part No. 05-1334-R	2
G12-G48T5	2
GPH212-GPH1148T5	1

This ballast may be acceptable for use with lamps not listed here. Contact us to discuss your requirement.



# **Wiring Diagrams**




NOTE: For 4-Pin Single Ended Lamps, See Wiring Diagram Below.

## Wiring Jumper Detail

For Miniature Bipin and Medium Bipin Lamps, add jumper between socket contacts of the lampholder before connecting the RED and YELLOW wires.

#### Connections

## 4-Pin Wiring Diagram (Single Ended)



### **Typical Instant Start Ballast Connections for Preheat Lamps**

The information and recommendations contained in this publication are based upon data collected by the Atlantic Ultraviolet Corporation® and are believed to be correct. However, no guarantee or warranty of any kind, expressed or implied, is made with respect to the information contained herein. Specifications and information are subject to change without notice.